

CERTIFICATE

This certifies, that the company

Omal S.p.A.

**Via Ponte Nuovo 11
25020 Rodengo Saiano (BS)
Italy**

Is authorized to provide the product mentioned below

Description of product: **High pressure floating ball valve series H2 Invictus**

In accordance with: **EN 61508:2010 Parts 1, 2, 4, 5, 6, 7**
The product meets also the requirements of standard EN 17955:2024

Registration No 26 27336 01
Test Report No PS-2733625-M
File reference 27336-01



TÜV Nord Italia S.r.l (TÜV NORD Group)
Via Turati, 70 – 20023 Cerro Maggiore (MI) – Italy

www.tuev-nord.it



Validity
from 2026-04-14
until 2029-04-14

Cerro Maggiore, 2026-04-14
prodotto@tuev-nord.it

Type	A
HFT	0
Safety functions	1. Close / Open upon the demand of the actuation system 2. Close upon the demand of the actuation system, with inline tightness when in closed position
Mode of operation	Low Demand Mode

Random failure rates				
Configuration	Safety function	λ_{DU} [1/h]	λ_{DD} [1/h]	λ_S [1/h]
Series H2 Invictus - No PST	1	3,47E-08	0,00E+00	0,00E+00
Series H2 Invictus - With PST	1	3,12E-09	3,15E-08	0,00E+00
Series H2 Invictus - No PST	2	4,19E-08	0,00E+00	0,00E+00
Series H2 Invictus - With PST	2	1,03E-08	3,15E-08	0,00E+00

Systematic capability	3 (Route 1 _s applied)			
Architectural constraints	Route 1_H:	Applied	Route 2_H:	Applied
	The product can be used in: <ul style="list-style-type: none"> • single channel configuration: <ul style="list-style-type: none"> ○ up to SIL 2 without external diagnostic tests ○ up to SIL 3 considering external diagnostic tests (only for Safety Function 1) • double channel configuration: up to SIL 3 			
Remarks:	<ul style="list-style-type: none"> • For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manual SM20250912 			

