



Italia

Scegli la certezza.
Aggiungi valore.

FIRE SAFE TEST CERTIFICATE

FLOATING BALL VALVE SPLIT WAFER

Size: 4"

Class: 150 LBS

Drawing: Y_1441

CERTIFICATE NUMBER: FS-063579-026

CLIENT: OMAL S.p.A.
ADDRESS: Via Ponte Nuovo, 11
25050 Rodengo Saiano (BS) Italy

REPORT NUMBER: 1175

SCOPE OF REPORT: Fire Safe test carried out according to:
API 6FA Third Edition April 1999

For further details of test arrangements and test results , see REPORT OF
FIRE TEST No. 1175 herewith attached and duly endorsed

TÜV
INSPECTOR

CERTIFICATION DATE

MANAGEMENT OF INSPECTION
SERVICE

	<input type="checkbox"/> Review
	<input checked="" type="checkbox"/> Witness
Date: <i>13/09/2010</i>	Name: <i>RS</i>

13/09/2010



TÜV ITALIA S.R.L.
TÜV SÜD Group

Telefono: +39 02 24130.1
Telefax: +39 02 24130.399

Amministratore Delegato:
Roberto Majocchi

Direzione e Sede Amministrativa:
Via Giosué Carducci, 125 edificio 23
20099 Sesto San Giovanni (MI)
Sede legale: Via Mauro Macchi, 27 20124 Milano
Società soggetta al controllo e al coordinamento di
TÜV SÜD AG

www.tuv.it

Registro delle imprese di Milano
n. iscrizione e Cod. Fisc. 08922920155
R.E.A. 1255140 - P. IVA 02055510966
Capitale sociale : Euro 500.000 int. vers.
Coord. Bancarie: INTESA BCI - CIN J
c/c 000018978166 - ABI 03069 - CAB 32934
IBAN: IT34 J030 6932 9340 0001 8978 166

TÜV ITALIA S.R.L.
 TÜV SÜD Group
 Via Giosuè Carducci, 125 edificio 23
 20099 Sesto San Giovanni (MI)
 Telefono: +39 02 24130.1
 Telefax: +39 02 24130.399
 www.tuv.it



Italia

FIRE SAFE TECHNICAL REPORT

FIRE SAFE CERTIFICATE N°: FS-063579-026

CLIENT DOSSIER N°: 1175

CLIENT: OMAL S.p.A.
ADDRESS: Via Ponte Nuovo, 11
 25050 Rodengo Saiano (BS) Italy

QUALIFIED VALVE

<u>VALVE SIZE:</u>	4"
<u>VALVE RATING CLASS:</u>	150 LBS
<u>DRAWING N°:</u>	Y_1441
<u>VALVE TIPE:</u>	FLOATING BALL VALVE SPLIT WAFER
For further details of test arrangements and test results , see REPORT OF FIRE TEST No. 1175 herewith attached and duly endorsed	

<u>RANGE AND TYPE OF VALVES COVERED:</u>	Size 4";5";6";8" DN 100;125;150;200 Class #150; #300
--	--

THE ABOVE MENTIONED VALVE SUCCESSFULLY PASSED THE FIRE SAFE IN ACCORDANCE TO:

API 6FA Third Edition April 1999

NOTES:

<u>LOCATION AND DATE OF TEST CARRIED OUT:</u>	OMAL; 13/09/2010
---	------------------

TÜV
INSPECTOR

	<input type="checkbox"/> Review	<input checked="" type="checkbox"/> Witness	
Date: <u>13/09/10</u>	Name: <u>[Signature]</u>		